

SAP E & C ALARM ANNUNCIATOR TRAINER
(PRODUCT CODE: SAP – 72)



TEMPERATURE PROCESS
PANEL (OPTIONAL)

ALARM ANNUNCIATOR PANEL

The **Alarm Annunciator Trainer (SAP – 72)** gives idea regarding its use in industry for monitoring, alarm and control process plant parameters.

ALARM ANNUNCIATOR TRAINER (SAP - 72)

Technical Specification: -

No.	Item Name	Technical Specifications
1	Alarm Annunociator Panel-	M.S. Powder coated, with toggle switches, Test Points, DIN rail Channel. Proper insulated Lugs, Ferruling & Neat wire Dressing & Clamping. Wires & power cables are seated through 1''x1'' PVC cable tray
2	Alarm Annunciator-	No. of windows: 4/6, Supply 230 V AC, Fault input contacts:- NO/NC, Window size:25x 30x 15mm, Cutout size:92x92mm (4 window) and 172x92mm (6 window)
3	Level Switch-	Float Type, 24 V DC, Float Material: SS304, Switching Current: 0.5A
4	Temperature Cabinet (SAP-69) (Optional)-	With Thermostat & Temp. Indicator & Controller, RTD Temperature Range: 0 to 100°C

Range of Experiments-

- ❖ Study of Alarm Annunciator Trainer

Features: -

- ❖ Compact Ergonomic Design.
- ❖ User Friendly, Self Explanatory Systems.
- ❖ Training Manuals mimic Charts for Operation Ease.
- ❖ Fast response time
- ❖ Inbuilt hooter

Services Required-

- ❖ Electric Supply of 1ϕ 230 VAC, 50Hz

Note-

All descriptive matter and illustrations are intended to give only a general idea of the equipment Detailed specifications may be altered at the company's discretion without any notice.

Manufactured/Marketed By
SAP ENGINEERS & CONSULTANTS

Regd. Off. : Shop No. 26-27,'Srushti', Survey No.82, Near Guru Ganesh Nagar,
Eklavya College Road (D.P.Road), Kothrud, Pune - 411 038

Telephone : (020) 2538 4737

Mobile : 94220 88946, 95524 75082

Fax : (020) 2538 3544

Email : pravinsdeode@vsnl.net, sapengineerspune@gmail.com

Website : www.sapengineers.com / www.sapengineers.co.in

For More Details Visit Our Website At: www.sapengineers.com, E-mail:- pravinsdeode@vsnl.net
SAP Engineers & Consultants, Kothrud, Pune-411 038. Ph-(020)25384737